

2015 ISOE Asian ALARA Symposium  
Tokyo, Japan, 9-11 September, 2015

# Considerations on Radiation Shielding Safety Review of High Density Storage Racks Additionally Installed in Spent Fuel Pools



9 Sept., 2015

Byeongsoo KIM



한국원자력안전기술원  
KOREA INSTITUTE OF NUCLEAR SAFETY

# Contents

- 
- Major Nuclear Facilities in Korea
  - Framework of Spent Fuels Management & Inventory of SF
  - PECOS Recommendation
  - Expansion of Storage Capacity & High Density Racks
  - Case Study : Additional Install of High Density Racks
  - Considerations on Radiation Shielding Safety Review
  - Conclusion

# Major Nuclear Facilities

## □ Nuclear Power Plant (NPP)

- ◆ 24 units in operation and 4 units under construction  
→ OL for Shin-Wolsong Unit 2 granted in Nov. 2014
- ◆ 2 units under PSAR review for CPs
- ◆ Kori Unit 1 : (June 16, 2015) Decommissioning Decision  
(after June 19, 2017) Permanent Shutdown

## □ Research Reactor (RR) / Education Reactor (ER)

- ◆ HANARO (RR)
- ◆ KRR 1 and 2 (RR, under decommissioning)
- ◆ AGN (ER)


## □ Nuclear Fuel Cycle Facility (FC)

- ◆ Fuel Fabrication Plant for NPP
- ◆ Fuel Fabrication Facility for RR
- ◆ Post-Irradiation Examination Facility (PIEF)
- ◆ Uranium Conversion Facility (released from regulation)


## □ Radioactive Waste Management Facilities (RW)

- ◆ RI Waste Management Facility
- ◆ Wolsong LILW Disposal Center (WLDC)  
→ in operation since 2015 (First disposal on July 13, 2015)

(As of Sept. 1, 2015)



# Framework of SF Management




# Inventory of Spent Fuels

**Total 13,812.02 MTU**

- KHNP: 13,807.84 MTU (99.97%)
- KAERI: 4.18 MTU (0.03%)

(As of Dec. 2014)



# PECOS : Establishment and Operation

## ❑ Establishment of **Public Engagement Commission on SFM (PECOS)** for National Policy


- ◆ The 2<sup>nd</sup> meeting of AEPC (Atomic Energy Promotion Committee) in Nov. 2012
  - Decision to revisit the national policy for SFM based on public consensus for mid- to long-term perspective
  - As part of efforts, decision to establish PECOS, **an independent advisory body**, established in October 2013 to perform public engagement activities
- ◆ On June 29, 2015, PECOS recommended **public-consulted management options for SF**, as a candidate national policy to the Government, MOTIE (Ministry of Trade, Industry and Energy).
- ◆ On June 30, 2015, PECOS officially stopped its operation and activities.
- ◆ The Government will decide on possible changes to the **policy for SFM based on the PECOS recommendations**.



<https://www.pecos.go.kr>

# PECOS : Activities and Recommendation


## Preparation of Consent - Based SNF Management Options to Protect People Safety



- **Brief Summary of 10 Recommendations (June 29, 2015) by PECOS**
  - **New interim SF storage facilities** (PWR: by 2024, PHWR: by 2019)
  - **New SF disposal facilities** (by 2051), Site Selection of URL (by 2020), Start of research in URL (by 2030)
  - New Public Monitoring Center, Fund, Licensee, **Standards, Law** & Agency responsible for R&D, SFM


# Expansion of Temporal Storage Capacity of SF

- Various ways to expand temporal storage capacity of spent fuels
  - This presentation is about **Additional Install of High density Racks** in Spent Fuel Pools.



# Install of High Density Racks in SFPs of NPPs

- After 1995, existing NPPs began to install high density (HD) racks.
- 10 units **replaced** existing normal racks with high density racks.
  - Kori Unit 3 & 4 : Replacement with HD racks in 2002 & 2006.
  - Hanbit Unit 1, 2, 3 & 4 : Rep. HD racks in 2007, 1997, 2006 & 2006.
  - Hanul Unit 1, 2, 3 & 4 : Rep. HD racks in 1995, 2005, 2008 & 2008.



- However, Kori Unit 1 & 2 and CANDU reactors (Wolsong Unit 1, 2, 3, 4) don't install high density racks.
- KSNP & New NPPs are designed to have high density racks in SFP.
  - First, at **construction stage**, only 50 % of HD racks are installed.
  - Later, at **operation stage**, **additional install and re-racking** of HD racks.
    - Hanbit Unit 5, 6 : additional install of HD racks in 2012 & 2012.
    - Hanul Unit 5, 6 : additional install of HD racks in 2008 & 2013.
    - ShinKori Unit 1, 2: additional install of HD racks(planned in 2015~16)
    - ShinWolsong Unit 1, 2 : additional install of HD racks (planned)
    - ShinKori Unit 3, 4 : additional install of HD racks (planned after OL)
- For reference, ShinKori Unit 5, 6 are designed to have two SPFs to accommodate all spent fuels for its design life of 60 years.

# Case Study : Additional Install of High Density Racks


- During 2014~2015, safety reviews were made for additional install of high density racks in spent fuel pool of NPPs whose operation began in 2011 and 2012.
  - All items related to nuclear safety, such as criticality safety, structural safety, seismic safety, thermal hydraulic safety, accident safety, and radiation shielding safety were reviewed.
- For above NPPs, **3-Step Approach** (20 years – 10 year – 25 years) was applied to fill SFP with High Density Racks.
  - For reference, different approach could be applied to different NPPs.

3-Step


20 yrs

10 yrs


25 yrs



In original design, high density racks are installed in SFP to accommodate spent fuel assemblies **for 20 years**. (1150 fuel assemblies)



At the stage of construction, SFP was filled with high density racks **just for 10 years**.



At the stage of operation, SFP is **fully filled** with high density racks **for 25 years** (original 20 years + additional 5 years : final total assemblies are 1450). Increased SFP capacity is about 26% compared with original design.

# Considerations on Shielding Safety Review

- Review items for radiation shielding safety review
  - **Shielding capability of the cooling water of SFP**
    - Represented as the limitation of pool surface dose rates (25  $\mu\text{Sv/hr}$ )
      - Additional inquiries such as geometry modelling, materials, code input files and output files are required to identify the pool surface dose rates.
        - ⇒ For MCNP, identification of proper use of Variance Reduction Technique and pass of all statistical tests and relative errors.
      - If necessary, confirmatory calculation is performed by using different approach to evaluate the surface dose rates or some reference values.
    - Shielding capability of SFP water : identified as much enough to limit the surface dose rates even in case of the increased fuel assemblies.
  - **Effect on radiation zoning** due to increased spent fuel assemblies
    - Radiation zone 2 (1~10  $\mu\text{Sv/h}$ ) on accessible regions inside fuel building
    - Radiation zone 1 (< 1  $\mu\text{Sv/h}$ ) on the outside surfaces of fuel building
    - No effect : identified by asking additional inquiries for dose rates
  - **Effect on shielding source terms** applied to design shielding capability of SFP cooling and cleanup system due to the increased
    - No effect : identified by asking additional inquiries for evaluation procedures of shielding source terms

# Conclusion

- Install of high density storage racks in SFP is to expand the temporal storage capacity of spent fuels in NPP.
- In Korea, since 1995, high density storage racks have been installed in SFP.
  - Now almost existing NPPs have been equipped with high density racks in SFP **by replacement or additional install.**
  - There still **remain regulatory needs** for safety review for newly-constructed NPPs whose storage capacity have not been yet expanded.
- Considerations are drawn on review items necessary to assess the radiation safety of high density storage racks.
  - These considerations can be helpful to standardize radiation shielding safety review activities until fully-developed safety review guides are prepared for additional install of high density storage racks in spent fuel pools in NPPs.

# Thank You.

