

2018 ISOE/ NATC ALARA Symposium

Patricia J. Robinson, (n,p) Energy, Inc

January 9, 2018







- US DOE R&D Laboratory for Nuclear Technology
 - Discover science and technology, where challenges are solved for the Medicine, Space, National security and Nuclear Technology
 - □ \$4 Billion R&D Annual Budget
 - □ 118 R&D 100 awards since 1978
- Invented and Patented, Polymer Filtration Technology™
 - ☐ Exclusive World-Wide Grant of Licensed Inventions to NPE
 - □ R&D 100 Award-Polymer Filtration Technology
- LANL- NASA Mars Curiosity Rover- Powered by Radioisotope Thermoelectric Generator (RTG) produced at LANL
 - □ Chem-Cam Laser Sensor- Developed at LANL
- (n,p) Energy, Inc. (NPE)
 - ☐ (n,p) Energy, Inc.- Single and Sole Licensee of LANL Invention
 - □ NPE is <u>not</u> a Resin Vendor... We provide a 2 Part Engineered solution

Corrosion Product Formation, Transport and Deposition -- A Dynamic Complex Set of Mechanisms




Figure 4.2. PWR Corrosion product, transport, and deposition mechanism (Rodliffe et al, 1987, by courtesy of IAEA)



CRUD

- Corrosion Products Released from System Surfaces
 - ☐ Ionic Forms (Soluble)
 - □ Particles (Insoluble)
 - > 0.1 um and Mechanical Filterable
 - Colloids (Insoluble, Can Agglomerating to Particles Given Time or Chemistry)
 - .001 um < 0.1um
 - Can't optically see them, Need SEM, TEMS
 - □ Co-deposited lons/Colloids/Particles
- Particles and Colloids Deposit on Surfaces by
 - **☐** Gravity (big particles) in Low Flow Areas
 - □ Crud Diffusion and Ion Exchange In Oxide Films
 - □ Surface Charge Attraction
 - □ Co-Precipitation of Different Species
 - □ Precipitation at over-saturation due to boiling




What is a Colloid in NPP?

- Insoluble And NOT Mechanically Filterable in Rx Systems
 - Extremely Fine Insoluble, Electrostatic, Material Suspension
 - □ Control Rod Reposition at Power:
 - 10,000,000 to 50,000,000 P / Liter (<0.6 um)
 - □ Dominantly... Iron Species (Fe) During Shutdown
 - 50,000 X More Fe than Co-60 in BWR RC
 - 5,000 X More Fe than Co-60 in PWR RCS
 - Think Tiny Clusters of Elements Together e.g. Fe, O, H
 - Iron Oxyanions Co-Incorporate Co-58, Co-60
 - □ Not Much Weight/Mass....Settle Times is in Years

Particle Size (μm)	RHR/SDC Cooling Pipe ID 12 in, t to 25% settling	RHR/SDC Cooling Pipe ID 12 in, t to 50% settling	RHR/SDC Cooling Pipe ID 12 in, t to 100% Settling
10	8 min	16 min	33 min
1	15 hr	27 hr	55 hr
0.1	57 days	115 days	230 days
0.01	1.5 yr	3.2 yr	6.3 years

Limitations of Chemistry Measurements Soluble: Is Really Soluble + Colloidal





Particles Partition in Fluids Colloids Can Also Partition in Fluids


- Not all coolant particles travel at the same velocity within RCS Pipe.
 - □ Laminar Flow- Parabolic Big particles towards center
 - □ Turbulent Flow- Fairly Distributed across pipe
 - □ Pipe wall Velocity is essentially zero and Velocity increases the further from the wall
- This is why deposition is different in Different Locations of RCS
 - Reynolds Number is Dimensionless number comprised of physical characteristics of flow, e.g.fluid mass density, gravity, fluid viscosity, average velocity and diameter of pipe

 $N_R = \rho v D / \mu g_e$




Particles Partition in Pipe Flow Big Particles to Centerline Pipe

Pipe wall velocity Approaches 0




e.g. CVCS, RWCU



Ball Valve X-Sectional Look at Flow Distribution Computational Fluid Dynamic

- FLUENT CFD Code Analysis
- Deposition
 - ☐ Zero Flow Areas in Darker Blue
 - ☐ Highest Flow Areas in Red





Special Colloid Transport: Partitioning BWR Fuel Channel Boiling Regime




Gas- Colloid Transport into RVH, CRDs, Cavity Surface


> Partitions colloids up into RVH and **CRDs and Cavity**


Mechanism Gas Phase Transport

Peroxide Injection

Fuel Boiling










Source Term Reduction: Two Part Solution BWR & PWR

Optimization of Shutdown Methods to Full Enable Technology





What Was the Innovation? **Coolant Purification Media, Unique Functions**




- Based on Technology from LANL, Department of Energy
 - □ R&D Effort: Took 20 yrs and \$20 M
 - □ New Compositions of Matter, New Polymers
 - ☐ Technology Used in LANL Nuclear Weapon Pit Facilities Separation of Pu and Am
 - ☐ Intellectual Property Protected
- Looks Like an Ion Exchange Resin, Bead or Powdered
 - ☐ Integrates into Existing Plant Purification Systems
 - ☐ RWCU, SFP, Suppression Pool, CPS
 - □ CVCS Demin
- Works Like BOTH:
 - □ Ion Exchanger (sol) +
 - □ Electrostatic Nano-Hair Particle Filter (colloid)



How is PRC-01M Bead, PRC-2 Powdered Used?

Existing Plant Systems CVCS, SFP, RWCU, CPS, FPC

- PWR: PRC-01 (bead) or BWR: PRC-2 (powdered)
- Existing Plant Equipment



PWR/BWR Deep Bed Vessel

PWR: Uses CVCS
Demineralizer Vessel

☐Both: Spent Fuel Pool

□Submerged Demin

□BWR: Filter/
Demineralizers

■RWCU

■FPC

■Suppression Pool




BWR
Precoat Filter/Demin




- High pH 7.2 to 7.4?
- Low pH 6.9 Modified ?
- Non Zinc Injection Plants?
- Zinc Injection Plants?
- Failed Fuel Cycles?

- High Duty Cores?
- Low Duty Cores?
- B&W Units?
- W Units ?
- CE Units?

VC Summer Benchmark Dose Rate Data for Outage Dose Performance




VC Summer RF 12 to RF 18 History of Benchmark Dose Rates During Cooldown





VC Summer RFO 16, 17, 18 Baseline Dose Rates During Shutdown




Hours After Mode 3



VC Summer- Impact on Critical Path as **Source Term Declines**

VC Summer - High Duty Cores Co-58 Peak Reduction- All PRC RFOs



R12 had 1 peak in AR 2.42 and a second at FO2 3.32 totalling 5.7 uCI/cc.

VC Summer Impact of Reducing Core Crud with NPE/PRC-01 Solution ONLY ---

No Ultra-Sonic Fuel Cleaning - No Zinc Inj


2003 Highest Power Zone Cycle 14 (grid 6)

2006 Highest Power Zone Cycle 16 (S33)

3rd RFO with NPE/PRC-01 Solution




After 6th RFO with NPE/PRC-01






VC Summer: Suspended Using PRC-01 R22, R23 Result: Increased Dose Rate 24%- 29%





NPE/PRC-01 Impact on Declining Peak Co-58 Farley-2 (W 3L, Post SGR) Zn Inj


Farley U2 Co-58 Peak w PRC-01 Trend Analysis Declining



Note: PRC-01 used for U2R14 SGR outage.



NPE/PRC-01 Impact on Declining Peak Co-58 Turkey Point-3 Lead PRC Rx (W 3L, old SG) No Zn




Note: Peak value is adjusted for active volume at time of peak. For example, R20 peak 0.7 μ Cl/cc actual with No RCPS, which is equivalent 0.35 with RCPS (factor of 2 dilution) R18, R19 full RCS system crud burst, R20 Core/RHR only No RCPs running.

Forecast R21 March 2004; 0.11 µCl/cc Full RCS, or 0.22 µCl/cc Core/RHR Only



NPE/PRC-01 Impact on Declining Peak Co-58 Turkey Point-4 Lead PRC Rx (W 3L, old 690 SG) No Zn





Forecast R22 March 2005: 0.085 µCi/cc Full RCS, or 0.17 µCi/cc Core/RHR Only




NPE/PRC-01 Impact on Declining Peak Co-58 St. Lucie Unit 1 and Unit 2 (CE Design, Old SG)








NPE/PRC-01M Impact on Declining Peak Co-58 DC Cook-1 Ice Condenser (W 4 Loop, I-690 SG) No Zn




NPE/PRC-01M Impact on Declining Peak Co-58 Braidwood-2 (W 4 Loop, Old SG), Zn Inj, HD Core

Braidwood A2R18 Peak Actual/ Forecast






NPE/PRC-01M Impact on Declining Peak Co-58 Three Mile Island-1 (B&W, 2 Loop New SG) Zn Inj





Zinc Injection Plants How do we know it's NOT Zinc?

EPRI Zinc Injection
SRMP Dose Rate Reduction from Natural & Depleted Zinc Injection
EPRI Doc: 1001020




Reference: EPRI 1001020 plus new DCPP cycle 10 and data; A1R16




Braidwood-1: SRMP Dose Reduction Greatly Exceeded EPRI Data Forecast

A1R16, A1R17, A1R18 with NPE/PRC-01M Cycle Zinc Exposure vs. SMRP Dose Rate Reduction Benchmark to EPRI Data



Reference: EPRI 1001020 plus new DCPP cycle 10 and data; A1R16


Braidwood-1 Old Sequence, Commercial Macroporous Type Resin





Braidwood-1 Reversal of Trend for Peak Co-58

- Peak Co-58 is a Measure of Core Crud being Released from Fuel. The higher the peak, the more total curies released.
- Goal is to have Peak As Low As Possible













Vermont Yankee R25 to R26 Results PRC Use R25 RFO, Cycle, R25 May 2007

- **-48.**%
 - ☐ Decline IVVI RWP Dose
 - ☐ 16.76 REM Planned IVVI RWP Dose
 - □ 8.172 REM Actual IVVI RWP Dose
 - □ Declined: -48%
- **-43.4** %
 - ☐ Drywell RWP Dose— DOWN Posted HRA
 - ☐ 21.21 REM Planned RWP Drywell Dose
 - ☐ 12.0 REM Actual RWP Drywell Dose



Vermont Yankee BRAC HWC NMC, Zinc Injection Last ½ C27







Monticello R22: RP Reports 1st BWR Use 2005 RF0-Lead BWR

- Chemistry- HWC, Zn injection, No NMC
- Contamination Levels Lower--- Throughout Plants
 - ☐ Turbine side reduced by 50%
- 40 % Quarterly RWCU Dose Rate Decline
 - ☐ Measured Before RFO and 120 Days at Power
- FuelFloor Activities
 - □ 30% decline in effective dose rate
- RFO: Refueling Cavity Decon Shorter
 - ☐ 6 hrs Shorter for REDUCED Cavity Decon
 - ☐ Critical Path Savings: \$180,000
- Fuel Floor: Equipment Removed " Cleaner"
 - Going In Cavity: 2,000,000 DPM/ 100 cm2
 - Coming Out: < 100,000 DPM/100 cm2



Monticello R22 to R23 Results

PRC Use RWCU for R22 RFO, Cycle, R23

- -28%
 - □ Decline in BRAC Points
 - ☐ Main Circuit Piping- Standardized Locations
 - □ Declined 28.5 %
- -38.5%
 - □ Decline RPV Effective Dose Rate
 - \square R22: EDR =1.45 mRem/RWP-hr
 - \square R23: EDR = 0.89 mRem/RW-hr
 - □ Change: 38.5 %
- **■** -71.1 %
 - □ Fuel Floor (Fuel Move/Inspection/CRB Replace)
 - □ R22: 0.78 mRem/RWP-hr
 - □ R23: 0.21 mRem/RWP-hr
 - □ Change: 71.1 %
- Monticello Low Dose CRE, May 2017 RFO



Peach Bottom-3R15

Oct-2005: Reported Results

- Chemistry: HWC, NMC, Zinc Injection
- Drywell Down Post LHRA to HRA
 - ☐ 1st time ever
 - ☐ Reduced Drywell Hot Spots
- Refuel Floor- Favorable Conditions Attributed to PRC
 - □ Superior Water Clarity
 - □ No Hot Particles on Fuel Floor
 - ☐ 6 PCE's Personnel Contaminations on FF
 - □ Rail Dose Rates Rapidly declined from flood up 10 to 15 mR/hr to 2 to 4 mR/ hr held constant through RFO



Peach Bottom-3R15 (PRC-02) Benchmark to Limerick-1(NO PRC)

- Rx Cavity Work Platform
 - ☐ 12 REM Limerick RWP Exposure; 10 to 60 mR/hr GA
 - ☐ 3 REM Peach Bottom Exposure; 2 to 10 mR/hr GA
 - ☐ -7 REM for work on platform
- Platform Post Removal Dose Rate
 - □ Limerick: 60 to 200 mR/hr Contact Platform
 - □ Peach Bottom-3: 2 to 6 mR/hr Contact Platform
- Contamination Levels
 - ☐ Limerick: 2 to 4 Rad/100 cm2 Smearable
 - ☐ PBAPS: 200K dpm /100 cm2 Smearable



Peach Bottom 2R16:

Rx Cavity Work Platform- Exceptional

Dose Rates & Contamination Levels- Post Removal

- Rx Work Cavity Platform in Cavity: 2 to 5 mR/hr in tub
- 98% of RCWP Area: < 100,000 dpm/100 cm2
- RWCP Removed:
 - □ Dose Rates Contact:2 to 12 mR/hr
 - □ Dose Rate General Area: < 2 mR/hr</p>
 - ☐ Hot Spots: 4 Locations, 15 to 20 mR/hr
- No Discrete Radioactive Particles on RCWP or Personnel
- Important Success Actions:
 - ☐ Hydro-Spray: Once Per Shift
- Drywell:
 - Down Post: LHRA to HRA
 - ☐ Reduced Drywell hotspots post core spray flush
- Station Low Dose Record Achieved



Perry 2017 RF16March 2017

- Implementation of Comprehensive STR Plan
 - □ RWCU Decon DF 2-3, and RC Risers
 - ☐ Hydrolazing Ports Installed
 - □ Permanent Shielding Install
 - □ PRC-02 RWCU
 - □ PRC-01M: FPC, Cavity, 4 Submerged Demins
- Perry 2nd Lowest Dose CRE, Spring 2017
- Reduced CRE 100 REM 1RF15 to 1RF16
- PRC Planned Continued Use to Reduce Post Decon Recontamination Rate.



Acknowledgements

- LANL Research Team Lead by Dr. B. Smith
 - □ 20 Yrs of R&D
- FP&L Turkey Point and St. Lucie- Chemistry, RP, Engr.
 - ☐ Supported All Development Work
 - 2 years of Testing
 - ☐ First of a Kind Engineering Use in 2000
- VC Summer- Chemistry and RP




Questions?



Email:patricia.robinson@npenergywater.com

Cell: 1-360-561-2000







Critical Operational Actions for RFO Source Term Success

BWR RFO:

- Maintain RWCU Maximum Flow Rate
 - ☐ Both RWCU Filter/Demins In-Service
 - ☐ RWCU Clean-Up Goal
 - □ Use Submerged Demins in Cavity
 - ☐ Recover RWCU as Soon as Possible for Start-Up

PWR RFO:

- Maintain CVCS Maximum Flow Rate
 - Operate RCPs through Forced Oxygenation to 0.5 uCl/cc Co-58 before Last RCP Trip
 - ☐ Clean-Up Goal 0.05 uCi/cc Co-58 before Flood Up
- Must reach Acid Reducing Prior to Going to 1 RCP



Opportunities with NPE/PRC Solution Integrated

- Business Goals:
 - □ Critical Path Reduction
 - Reduced Core Curie Release
 - Reduced Final Cavity Decon CP-Time
 - ☐ CRE, Source Term Reduced, Sustained Dose Rate
 - LHRA/HRA's downposted to RA's
 - Sustainable Decline in Dose Rates, RFO to RFO
 - □ Overall Outage Performance Improvement
 - Resources
 - ☐ Fuel and Component Performance
 - Reduced Core CRUD Deposits and Component CRUD
 - ☐ LLW Disposal
 - Primary Resins to Class A
 - ☐ Liquid Effluents
 - Decline in Annual Release



Opportunities with NPE/PRC Solution Integrated

- Critical Path Reduction
 - Reduced Peaks, Shorter Clean-up CP Time
 - Final Cavity Decon Time, < 2 hours, Avoided 6 to 8 Hrs CP Time at \$30K/CP- Hr, \$90K/ RFO
- CRE, Source Term Reduced, Sustained Dose Rate
 - INPO Ranking
- Overall Outage Performance Improvement
 - Resources Worker Productivity Increase to Support Outage due to "Cleaner" system
- LLW Disposal
 - Primary Resins to Class A
 - Future Savings: \$400,000 / RFO
- Liquid Effluents
 - Decline in Annual Release
 - Stakeholder



Business Plan Objective: Reduce LLW Disposal Costs for Resins



Cost Now	(2 Unit Site)) :
----------	---------------	------------

- One Class B/C Resin Shipment: ~\$400,000 to \$500,000
- \square One Class A Resin Shipment: ~\$30,000 (\$300/cu ft, 200 cu ft)
- □ Current Class B/C Ship Rate: ~6 shipments every 3 yrs, \$3,000,000

Cost in Future:

- □ Class B/C Resin Shipment: One shipment every 3 yrs, \$500,000
 - Location: SFP Submerged Demin
- Class A Resin Shipments: ~5 shipments every 3 yrs, \$150,000

Additional Value WITH STR:

- □ Cost of implementation: \$250,000
- □ Savings: \$3,000K 250K (implementation) -30K (1 Class B) = \$1,800,000
- □ Added ROI: 6: 1 in 3 years;Added ROI: 12: 1 in 6 years



What is a Colloid?

- Chemistry
 - ☐ Insoluble but Not Mechanically Filterable in Rx Systems
 - ☐ Extremely Fine Insoluble Material Suspension
 - □ Dominately Iron (Fe)
 - 50,000 X More Fe than Co-60 in PWR RC at Rx Shutdown
 - ☐ Think Tiny Clusters of Elements Together e.g. Fe, O, H
- Colloid Cluster Size Range
 - \square Smaller than 0.1 0.001 μ m range
 - □ Not Much Weight/Mass
 - Settle Times can be Years
 - Think Millons of Colloids in 1 Liter at Shutdown
- Special Properties
 - □ Electrostatically Charged
 - + or Charge can Attract or Repel
- Can Cause Corrosion



What is PRC? Set of Medias with Multiple Enabled Functions

- Start with Conventional Resin used in NPP for 30 yrs.
 - ☐ Powdered or Bead Size Ion Exchange Resin
- Surface is Modified by Organic Polymers
 - ☐ Enabled for target contaminate:
 - Soluble and Insoluble Targeted Species Removal for PWR/ BWR chemistries
 - NPP PRC Enabled: Transition metals, transuranics
 - □ Polymer Nano-Hairs
- Polymers Can be Customized for SiO2, Sb, Cu, etc.



Acknowledgements/ References

- Radiochemistry of Light Water Reactors, Dr. Karl Neeb, 1997
- Westinghouse AP1000 Design Control Document
- Los Alamos N.L.- Technical Documents
- EPRI Documents, BWR VIP-190, 2010
- IAEA Publications
- Dr. M. Pourbaix, Eh- pH (1966) Solubility Diagrams
- Actinide 2001 Conference: "Thermodynamic Stability of Mixed Oxide Pourbaix Diagrams" P. Vitorge et al, CEA
- University of Illinois, UC, Dr. Barkley Jones, NE Department
- University of New Mexico, Dr. A. Hasan, Colloid Transport of Transuranics

Peach Bottom 2R16: Work Cavity Platform Dose Rates & Contamination Levels- Post Removal

WCP Rad Conditions:

• 98% of WCP Area:

 $< 100,000 \text{ dpm}/100 \text{ cm}^2$

• Hot Spots:

7 Bolts: 16 to 560 mRad/100 cm² Hinges: 48 to 96 mRad/100 cm²

• Dose Rate Removed:

Contact: 2 to 12 mR/hr < 2 mR/hr General Area

• Hot Spots:

4 Locations, 15 to 20 mR/hr

No Hot Particles on WCP

• No Hot Particles on Personnel

Actions:

1. FCP: 100% Availability, PRC-02 Precoated F/D Clean-up System, Max Flow Rate

2. Hydro-Spray: Twice/ Shift every day

