



Nuclear Power
Services

China Nuclear Power Engineering Co.,Ltd.

The Establishment and Application of Dedicated Dose Evaluation Models of HPR1000

Xiong Jun

China Nuclear Power Design Company(CNPDC)

2019 ISOE INTERNATIONAL SYMPOSIUM

Natural Energy Powering Nature

CONTENTS

/01/ Introduction

/02/ Method

/03/ Conclusions

/04/ Future Works

/1/ Introduction

HPR1000 The Gen III nuclear power technology with independent IPR of China

Thanks to 30 years of experience and expertise in NPP design, construction and operation, HPR1000, with completely independent IPR, has successfully been developed, based on the proven and safe technology and mature nuclear power equipment manufacturing system and capacity. HPR1000 is one of the most recognized Gen III technology in nuclear power market



/1/ Introduction

On Dec.24, 2015



FCG Phase 2 started its construction.

On Sep.29, 2016

After the Launching of HPR1000 in the agreements of UK projects, GDA was accepted in January, 2017.

Main Technical Features

The reactor core is composed of 177 fuel assemblies and 3 physically isolated safety trains.



HPR1000


Technical features

Design life	60 years
Plant layout mode	Single reactor
Reactor core	177 advanced fuel assemblies STEP-12
Core Damage Frequency (CDF)	$< 1 \times 10^{-4}$ /reactor year
Large Release Frequency (LRF)	$< 1 \times 10^{-7}$ /reactor year

Technical features

Design basis seismic	0.3g
Generator output	1150MW
Double containment	Able to withstand crash of large commercial plane
Nuclear DCS platform	FirmSys, which boasts independent IPR
Plant availability	Up to 90%

/1/ Introduction




/1/ Introduction

- Collective dose target value is ***also an important element/indicator*** for the optimization of radiation protection design of nuclear power plants.
- The dedicated collective dose evaluation model for the new design reactors should be established for ALARA analysis ***(Benchmark or Baseline)***.
- Based on the dose evaluation model, the ***systematic approach*** should be established and applied to evaluate all the relevant design features to achieve ALARA of the exposures ***(optimization)***.

/2/ Method - Considerations

- **Compliance requirements** – follow the codes, standard and guidelines(China, IAEA, etc.)
- **Based on operation experience(OPEX) feedback** – adopts relevant dose data from operating plants to predict and assess the collective dose; find and use good practice....;
- **Identification of potential improvements** – shortfalls identification;
- **Prioritization of the potential improvements** - high dose tasks are higher priority;
- **Identification the options for dose reduction** – hierarchy of control;
- **Continuous Optimization** – initial dose, optimized dose, further optimized dose;

Systematic dose assessment approach




/2/ Method - Steps and Key Points

Step1 Selection of International OPEX

Objective: use to establish the initial database, help to screen in the relevant good practice.

OPEX data mainly drawn from:

- Dose data from CGN OPEX units (M310 and CPR1000) in commercial operation in China;
- Operating experience data from NPPs around the world that has similar advanced design with HPR1000;
- Historical annual dose data for PWR plants in the world;




/2/ Method - Steps and Key Points

Step2 Establishment of Initial Dose Database

Objective: use to identify the high-dose activities / obtain ref dose for each tasks.

Database includes:

- Description of tasks related to dose activities;
- Exposed doses for each task;
- Exposed man-hours for each task.



RWP: Radiation Work Permit

查找历史RWP 查找RWP模板 RWP修改记录 RWP审批退回 附加要求文件 附件

RWP基本信息

RWP编码: 5000075 12REN115MP下方—电磁阀本体的侧面大量漏气。 RWP版本号: 1 RWP分级: 0 RWP类型: S

RWP状态: PLND

抬头数据 | 工序数据及风险安措分析 | 特殊提醒及附加需求 | RWP关闭 | RP录入信息 | 工作实际数据

负责人

计划员组: PMI / 5010 通知: 200001542547

维护中心: MIA / 纠正性维修

准备工程师: P970235 超 李 系统条件: N On-Line 日常

版本:

位置信息

功能位置: DY-2-14-REN-116MP 016RF冷却器下游压力变送器

房间功能位置:

是否控制区域相关: ☒

辐射分区:

剂量预估

工作点最大剂量率预估值: 0.1000 mSv/h 作业人数预估值: 2

工序工作点最大剂量率: 0.0000 mSv/h 个人单日剂量报警值: 8


剂量率报警阈值: 1.0000 mSv/h 集体剂量预估值: 8

个人最大剂量预估值: 0.1000 mSv 工序集体剂量: 8


设点信息

点文件: 工序号: 子工序: 整体工作要求: 编码:

Tasks;
Process;
Worker dose;
Area dose rate;
Man-hours



Initial Dose Database



Collect data from RWP/PDUS

Analyze the data

Identify the key information as category of tag

Establish the tag

Classify the data by activities categories

		H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z	AA	AB	AC	AD	AE
1	运行状态	RWP描述	专项组 (分类用)	部门	磁卡号	开始日期	开始时间	人工时	人员数	工单号	功能编码	部件分	系统	厂房	工单类型	RWP类别	RWP分级	RWP类型	版本	计划工	维护中	房间功能	进出区		
91725	outage	LARC002GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/检测公司/表面测		中广核检测	330432	42465	0.581354	3.02	0.069	800001091/LA-4-06-B/S/G	RCP	0	NFRV	301258	2	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92015	outage	LARC002GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/检测公司/表面测		中广核检测	330426	42465	0.805532	1.78	0.033	800001091/LA-4-06-B/S/G	RCP	0	NFRV	301258	2	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92098	outage	LARC002GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/表面		中广核检测	752060	42465	0.805718	1.84	0.012	800001091/LA-4-06-B/S/G	RCP	0	NFRV	301258	2	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92115	outage	LARC002GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/表面		中广核检测	345490	42465	0.577477	2.74	0.057	800001091/LA-4-06-B/S/G	RCP	0	NFRV	301258	2	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92580	outage	LARC003GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	751946	42465	0.450012	0.39	0	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92756	outage	LARC002GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/表面		中广核检测	752030	42465	0.577211	2.8	0.032	800001091/LA-4-06-B/S/G	RCP	0	NFRV	301258	2	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92791	outage	LARC001GW一次侧支腿RTS本体保固区PT5年大修专项/存得检查/表面		中广核检测	330418	42466	0.394271	2.39	0.051	800001091/LA-4-06-B/S/G	RCP	0	NFRV	301261	2	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92874	outage	LARC001GW一次侧进出口管嘴与安全端及安全端与主管道连接焊缝PT 10年			614877	42466	0.641771	2.01	0.004	800001091/LA-4-06-B/S/G	RCP	0	NFRV	301257	2	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92929	outage	LARC003GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330692	42466	0.382269	1.22	0.014	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92930	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330692	42466	0.627498	3.85	0.049	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
92974	outage	LARC001GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/检测公司/QC组		中广核检测	751929	42466	0.642303	1.99	0.001	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93035	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330702	42466	0.626019	3.84	0.039	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93079	outage	LARC001GW一次侧进出口管嘴与安全端及安全端与主管道连接焊缝PT 10年			345840	42466	0.630255	3.12	0.015	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93080	outage	LARC001GW一次侧进出口管嘴与安全端			345840	42466	0.392118	2.43	0.023	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93275	outage	LARC001GW一次侧进出口管嘴与安全端			324612	42466	0.641389	2.03	0.004	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93301	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330693	42466	0.627222	3.82	0.089	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93373	outage	LARC002GW一次侧进出口管嘴与安全端		中广核检测	330426	42466	0.418252	1.79	0.049	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93463	outage	LARC001GW一次侧进出口管嘴与安全端		中广核检测	345490	42466	0.642394	2.11	0.008	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93465	outage	LARC001GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/表面		中广核检测	345490	42466	0.393611	2.35	0.048	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93466	outage	LARC001GW一次侧进出口管嘴与安全端及安全端与主管道连接焊缝PT 10年			614876	42466	0.641134	2	0.005	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93631	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330694	42466	0.628681	3.8	0.146	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93656	outage	LARC001GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/检测公司/表面测		中广核检测	330401	42466	0.63081	3.11	0.015	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93661	outage	LARC003GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/检测公司/表面测		中广核检测	330414	42466	0.392905	2.35	0.04	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93670	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/工下: OTS/MTS		中广核检测	336051	42466	0.626458	3.15	0.023	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93795	outage	LARC003GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330709	42466	0.382083	1.21	0.014	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93796	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330709	42466	0.62891	3.83	0.069	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93829	outage	LARC003GW一次侧进出口管嘴与安全端及安全大修专项/存得检查/表面		中广核检测	752067	42466	0.392639	2.37	0.038	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93831	outage	LARC001GW一次侧进出口管嘴与安全端及安全端与主管道连接焊缝PT 10年			614878	42466	0.641991	2	0.005	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93911	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	751946	42466	0.627454	3.81	0.102	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
93975	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/检测公司/超声测		中广核检测	330706	42466	0.626586	3.86	0.096	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
94059	outage	LARC002GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330518	42466	0.627789	3.22	0.005	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			
94328	outage	LARC003GW管嘴与上筒体和下封头焊缝UT 5年大修专项/存得检查/超声		中广核检测	330702	42467	0.399491	3.58	0.034	800001091/LA-4-06-B/S/G	RCP	0	NFRV	3014266	1	S	LD405	5030	TSR CT C	LA-4-H-RK	1	Lingdong LA building			

Example Tags



Step2 Establishment of Initial Dose Database

Initial data includes 2 parts:

Initial annual collective dose

Initial distribution of collective dose

- ① Eliminate the inapplicable data;
- ② Classify the data into power, NRO, ISIO, and calculate the mean value to each category data;
- ③ Analyse the average value in an comprehensive outage arrangement of the plant;

	Collective dose in power operation	Collective dose in NRO	Collective dose in ISIO
Statistic of collective dose	0.104 man•Sv/yr	0.609 man•Sv/outage	1.357 man•Sv/outage
A comprehensive inspective cycle including	9 years	5 outages	1 outage
Initial annual collective dose	0.594 man•Sv/yr		

NRO: normal refueling outage

ISIO: in-service inspection outage

电厂机组	大亚湾1	大亚湾2	岭澳1	岭澳2	岭澳3	岭澳4	红沿河1	红沿河2	红沿河3	红沿河4	宁德1	宁德2	宁德3		阳江1	阳江2	阳江3	阳江4	防城港1	防城港2	非自然年数据
1994年	0.201	0.201																			12个月换料
1995年	0.990	0.990																			18个月换料
1996年	0.520	0.520																			意外事件
1997年	0.750	0.750																			十年大修数据
1998年	0.660	0.660																			商运前数据
1999年	0.670	0.670																			
2000年	0.560	0.560																			
2001年	0.680	0.680																			
2002年	0.370	0.370	0.026																		
2003年	0.920	0.920	0.761	0.761																	
2004年	0.910	0.910	0.500	0.500																	
2005年	0.640	0.640	0.540	0.540																	
2006年	0.600	0.600	0.360	0.360																	
2007年	0.530	0.530	0.620	0.620																	
2008年	0.410	0.410	0.890	0.890																	
2009年	0.632	0.084	0.864	0.667																	
2010年	0.556	0.391	0.519	0.407																	
2011年	0.060	0.933	0.859	0.534	0.701	0.004															
2012年	1.161	0.074	0.468	0.479	0.284	0.645															
2013年	0.892	0.877	1.861	1.377	0.252	0.325															
2014年	0.052	1.460	0.612	0.246	0.302	0.322	0.742	0.260													
2015年	0.990	0.045	1.285	0.334	0.312	0.285	0.347	0.671	0.008												
2016年	0.449	0.583	0.080	1.038	0.319	0.709	0.286	0.543	0.059												
2017年	0.056	0.656	0.809	0.108	0.729	0.471	0.626	0.029	0.549												

Annual Collective dose for each plant

	A	B	C	D	E	F	G	H
1								
2		大修代号			大修工期			
3			解列日期	并网日期	达满功率日期	解列至并网/天	解列至满功率/天	剂量/(人·mSv)
49	46	L109	2011/1/26	2011/2/23		29		765.338
50	47	L301	2011/8/25	2011/11/14		79.03		726.124
51	48	D215	2011/10/26	2011/12/11		46		839.669
52	49	L209	2011/12/12	2012/1/10		30		560.235
53	50	L110	2012/1/21	2012/2/10				379.359
54	51	D115	2012/4/8	2012/6/2				1090.362
55	52	L401	2012/5/10	2012/7/17				620.477
56	53	L302	2012/8/1	2012/9/6				257.022
57	54	L210	2012/12/12	2012/12/30		19		303.318
58	55	L111	2013/1/21	2013/3/21		59		1759.747
59	56	L402	2013/3/6	2013/4/16		36.68		266.279
60	57	D216	2013/4/12	2013/5/30		48.13		828.16
61	58	L303	2013/4/30	2013/5/31		30.99		216.595
62	59	D116	2013/10/17	2013/12/10		44.93		822.678
63	60	L211	2013/11/22	2014/1/17		56.29		1428.688
64	61	L403	2014/1/15	2014/2/16		32.88		273.489
65	62	L304	2014/3/21	2014/4/19		28.98		215.918
66	63	L112	2014/5/23	2014/6/23		31.78		525.388
67	64	D217	2014/10/4	2015/1/3		91.38		1394.286
68	65	L305	2014/12/25	2015/1/31		37.51		309.233
69	66	L404	2015/2/17	2015/3/22		33.2		238.946
70	67	L212	2015/4/18	2015/5/8		19.92		267.795
71	68	D117	2015/3/10	2015/5/24		75.3		937.126

Collective dose for each Outage

Step2 Establishment of Initial Dose Database

Initial data includes 2 parts:

Initial annual collective dose

Initial distribution of collective dose

Identify typical distribution of collective dose based on CPR1000 by analysing the OPEX data of the plant with relative long operation and good performance. (from RWP code)

- ① Identify the tasks performed during normal operation;
- ② Classify the dose data by tasks; (*according to: radioactive risk, organisation of work*)
- ③ Calculate the proportion of collective dose.

Classification of activities	Percentage of each classify activity	Initial annual collective dose
Reactor operations & surveillance	17.49%	594 man•mSv/yr
Worksite logistics	18.52%	
Reactor Coolant System	12.99%	
.....	

Collect data from
RWP/PDUS

Analyze the data

Identify the key
information as
category of tag

Establish the tag


Classify the data
by activities
categories

RWP数据				
维修类型	所属系统	部件类型	关键活动项 (参考经验)	运行工况
			运行相关活动	功率
			通用服务	停堆
NPRV 预防性维修	RCP	RPV	反应堆	
NSRV 监督试验	RCV	SG	燃料	
NMO 维修	RRA	主泵	SG等主设备	
	PMC	容器	阀门组	
	RIC/RPN	其它泵	泵组	
	废物处理	阀	在役检测	
	其它	除盐床	电仪控	
		过滤器		

分类关键词
Tags

Initial
distribution
of
collective
dose

Categories of
activities



Classification		dose proportion
Reactor operations & surveillance		17.49%
On-site Service	Scaffolding	2.18%
	Thermal insulation	7.31%
	Decontamination	2.31%
	Shielding	1.02%
	Working support	2.42%
Operation & maintenance related to the reactor	Others	3.28%
	Prepare For Refuelling Work	6.05%
	operation related to fuel assembly	2.58%
	maintenance related to the reactor	3.33%
RCP	Steam Generator(SG)	6.40%
	Reactor coolant pump	1.36%
	Pressurizer(PZR)	0.08%
	Valves	4.60%
RCV	Other equipment	0.56%
	Pump	0.20%
	Valves	4.83%
RRA	Other equipment	1.27%
	Valves	2.61%
	Pump	1.22%
	Other equipment	0.33%
Other systems	Valves	7.54%
	Pump	0.81%
	Other equipment	1.75%
Electrical, instrumentation and control		2.21%
In-service inspection		2.77%
Waste treatment	Radwaste handling	1.12%
	Radwaste system adjustments/repairs	0.21%
others		12.16%
total		100.00%


/2/ Method - Steps and Key Points

Step3 Identification of High Dose Activities

High dose tasks are with higher priority;


- The single activity with high individual dose;
- The most exposed group activities that contribute significantly to collective dose

Identification of high-dose activities	HPR1000	CPR 1000	HPC	NEA No.6975
Works involved SG	√	√	√	√
On-site service (including insulation)	√	√	√	√
Works involved valve inspection and maintenance	√	√	√	√
Works involved reactor pressure vessel	√	√	√	√
Waste processing	√		√	
In-service inspection	√	√	√	√



Identified high-dose activities:

- Works involved reactor pressure vessel;
- Works involved steam generator;
- Works involved valve inspection and maintenance;
- In-service inspection;
- Waste processing;
- On-site service
-





tasks	Man-hours (h)	Worker dose (mSv)	Proportion	Collective dose TOP10	Average personal dose mSv/h TOP10
SG/开关手眼孔	229.83	8.18	0.80%	4.78	0.0356
RCV/其它设备/换热器维检	287.75	9.26	0.90%	5.41	0.0322
RCP/其它设备/管道检修	429.67	11.04	1.08%	6.45	0.0257
RCV/其它设备/容控箱维检	107.47	2.66	0.26%	1.55	0.0248
SG/二次侧检查	533.53	12.49	1.22%	7.30	0.0234
在役检查/支撑和支架	323.75	7.47	0.73%	4.36	0.0231
RRA/换热器维检	139.79	3.18	0.31%	1.86	0.0227
SG/冲洗和干燥	812.13	18.32	1.78%	10.71	0.0226
通用服务/保温	3281.35	70.95	6.91%	41.46	0.0216
废物处理/放射性废物处理/工作准备	9.8	0.21	0.02%	0.12	0.0214
RCV/阀相关维检	3439.35	71.54	6.97%	41.81	0.0208
RCP/阀门相关工作	3113.17	44.79	4.36%	26.17	0.0144
其它系统/阀相关维检	8843.13	86.66	8.44%	50.64	0.0098
压力容器开关盖	6299.91	48.62	4.74%	28.41	0.0077
例行检测	15271.23	84.07	8.19%	49.13	0.0055
杂项	16017.75	38.44	3.74%	22.46	0.0024
其它工作	36994.08	65.84	6.41%	38.47	0.0018
系统运行和测试	36662.51	63.01	6.14%	36.82	0.0017
通用服务	36981.79	31.77	3.09%	18.57	0.0009

/2/ Method - Steps and Key Points

Step4 Identification of Options for Risk Reduction

Key point: establish a systematic method to identify the options: ***Hierarchy of control: (ERIC/PPE)***



➤ **Elimination:**

Eliminate the radiation sources or exposed activities to avoid the radiological risk.

- Remove the radiation source around the area of activities;
- Replace the manual tasks by fully automatic tasks; or
- Replace the near-distance operation by remote operation.

➤ **Reduction:**

Reduce the source term or the frequency and duration of the dose activities.

- Optimise the material selection, surface finishes, primary coolant chemistry control and decontamination to reduce the source term;
- Optimise the process design, system design and equipment design to be more convenient and robust to reduce the frequency and duration of the operation and maintenance.

➤ **Isolation:**

Isolate the radiation sources or contaminations from workers.

- Perform radiation zoning to isolate the high radiation areas from low radiation areas;
- Adopt appropriate shielding or containment to isolate the sources from workers.

➤ **Control:**

Implement administrative control to avoid unauthorised entrance or spread of contamination.

- Temporary access control to avoid unauthorised entrance;
- Ventilation control to avoid spread of contamination;
- Monitoring and alarm on radiation and contamination level to avoid excessive doses.

➤ **Personal Protective Equipment (PPE):**


Use appropriate PPE for radiological protection.

/2/ Method - Steps and Key Points

Step5 Selection of the Reasonably Practicable Options

Objective: *multi-disciplines analysis* to help make good decision of reasonably practicable options.

- Develop the assessment criteria and method for the potential options.
- Assess the performance of potential options against the criteria.
- Select the reasonably practicable option(s).




Example for optioneering

SG inspection and maintenance

Task	Activities	Collective Doses (man.mSv/yr/unit)	Percentages
Works involving steam generator (SG inspection and maintenance)	Inspection of primary side	10.60	28% ★
	Inspection of secondary side	7.65	20%
	Flushing and drying	11.22	30% ★
	Opening and closing of the manway	3.57	9%
	Opening and closing of the handhole and eye hole	5.01	13%

Percentage in SG Inspection & Maintenance



Example for optioneering



SG inspection and maintenance

Hierarchy of control	thinking	options	Reasonable practicable options?
Elimination	-Eliminate the radioactive source?	Impossible to eliminate SG since SG is an essential equipment for PWR.	No
	-Eliminate the dose activity?	Impossible to eliminate the inspection and maintenance for SG because they are always necessary to guarantee that the SG works in expected performance.	No
Reduction	-Reduce the source term?	•Reactor chemistry Improvement on pH control and adoption of higher enriched boric acid maybe possible.	Yes
		•Material selection Reduction of the use of cobalt-based alloy, Use of the alloy with better resistance to corrosion	Yes
		•Decontamination Higher decontamination efficiency by RCV filters and demineraliser. Decontamination of SG before inspection and maintenance.	Yes
	-Reduce the duration?	•Use of sludge trap to reduce frequency of flushing and drying of SG •Use of fast assembly/disassembly tools •Use of Fast assembly/disassembly insulation •Improvement of inspection techniques •Installation of permanent platform for inspection and maintenance •More training on mock-up, etc.	Yes
Isolation	•Radiation zoning and contamination zoning •Radiation shielding		Yes
Control	•Access control to avoid unauthorized entrance •Contamination control to avoid entrance of extra radioactive contamination		Yes
Personal Protective Equipment (PPE)	•Use appropriate PPE if necessary		Yes

/2/ Method - Steps and Key Points

Step6 Collective dose assessment

the collective dose is assessed by :




Example for dose assessment

SG inspection and maintenance


Based on optimization mentioned in the former slides, the collective dose for SG inspection and maintenance has been reduced.

Task	Activities	Collective Doses (man.mSv/yr/unit)	impacts	Optimised Collective Doses (man.mSv/yr/unit)
Works involving steam generator (SG inspection and maintenance)	Inspection of primary side	10.60	-10.00%	9.54
	Inspection of secondary side	7.65	-10.07%	6.88
	Flushing and drying	11.22	-50.00%	5.61
	Opening and closing of the manway	3.57	-10.08%	3.21
	Opening and closing of the handhole and eye hole	5.01	-9.98%	4.51


The use of radiation protection Optimization system




Core calculation model(MC method)




Geometry interface model




Source term interface model



Dose field Visualization model



Dose optimization model



Dose field modification model

/3/ Conclusions

/collective dose in HPR1000/

Improvement:

- source term reduction;
- Other Improvements (optimize equipment/layout/operation process design);
-

Weakness:

- Valves increasing for safety design;
-

In conclusion, optimized collective dose in HPR1000

is 565mSv/a (design value!);

Classification		Collective dose(man•mSv/yr)			
		Starting Point	Improvement impact for dose	Source Term Optimisation	Current Optimised Dose
Reactor operations & surveillance		103.88			
On-site Service	Scaffolding	12.97			
	Thermal insulation	43.45			
	Decontamination	13.72			
	Shielding	6.07			
	Working support	14.4			
	Others	19.46			
Operation & maintenance related to the reactor	Prepare For Refuelling Work	35.94			
	operation related to fuel assembly	15.32			
	maintenance related to the reactor	19.77			
RCP	Steam Generator(SG)	38.04			
	Reactor coolant pump	8.1			
	Pressurizer(PZR)	0.47			
	Valves	27.34			
	Other equipment	3.3			
RCV	Pump	1.19			
	Valves	28.68			
	Other equipment	7.56			
RRA	Valves	15.48			
	Pump	7.24			
	Other equipment	1.95			
Other systems	Valves	44.76			
	Pump	4.81			
	Other equipment	10.4			
Electrical, instrumentation and control		13.11			
In-service inspection		16.47			
Waste treatment	Radwaste handling	6.63			
	Radwaste system adjustments/repairs	1.24			
others		72.24			
total		594			26 565.24

/3/ Conclusions

- *Based on the operating experience data of CGN units, this report establishes for HPR1000 and implements it to help optimize the design and reduce effectively occupational radiation exposure to workers.*
- *The preliminary evaluation of the collective dose has been completed based on the HPR1000 specific information; the high dose activities and potential options for risk reduction have also been identified.*
- *The evaluated collective dose and the identified high dose activities have been compared with the comparable stations across the world and OPEX data from CGN units proved that they are reasonable and credible.*
- *For the high dose activities, take efforts with each relevant discipline to make sure the exposure risk is ALARA.*

/4/ Future Works

➤ *Strengthen the interaction with the utilities:*

- Get more OPEX feedback(data, good practice, weakness....).
- Establish standardized categories of activities with radiation risk and dose record method with the utilities(update RWP, more precise dose record.....).


➤ *Better use of the model and data:*

- **Continuously optimize** the categories and statistics method of the model;
- **Auto match** the data towards the tasks/activities categorization between the model and RWP.
- **Data mining** to find more valuable information for RP.

/4/ Future Works

➤ *Application of new technology:*

- Establish the link between 3-D dose field calculation and visualization system and dose management system;
- apply the new monitoring system and device to get more information automatically.
-



3-D dose field calculation and visualization system



Primary coolant real-time spectrum detector



Thanks for your attention