



**Los Alamos National Laboratory
Developed Technology Proven
Effective for Reducing Plant Radiation
Levels in Light and Heavy Water
Reactors**

**Asian ISOE ALARA Symposium
Tokyo, Japan
September 24-25, 2012**



**Presented by:
Patricia J. Robinson, (n,p) Energy, Inc.**



Presentation Outline

- **How do you Reduce Source Term?**
- **Value of Reducing Radiation Source Term**
- **Brief Review Technology Origin**
 - ❖ **Los Alamos National Laboratory Polymer Filtration™ Science**
- **Engineering the Solution for Each Type of Reactor Design**
 - ❖ **PWRs**
 - ❖ **BWRs**
 - ❖ **CANDUs**
- **Results**
- **Opportunity for Asian Lead Units**


How do you Reduce Plant Radiation Source Term?

- **Reduce Source Term by**
 - ❖ **1) Reducing CRUD on Fuel and**
 - ❖ **2) Reducing CRUD In Primary Circuit**
- **Sounds Simple --- But Required New Engineered Solution and New Invention**

Nuclear Fuel --Before



Nuclear Fuel -After





Initiative Value Proposition

- **Radiation Protection**
 - ❖ **Collective Radiation Exposure Reduction**
 - ❖ **Full Spectrum of Impact: Reduced...**
 - **Dose Rates,**
 - **Contamination Levels,**
 - **Hot Particles,**
 - **Number of Locked High Radiation Areas**

- **Component Reliability and Fuel Performance Improvement**
 - ❖ **Reduces Root Cause for Stage #1 Seal Reactor Coolant Pump (RCP) leak rate**
 - ❖ **Decreases CRUD Induced Power Shift (CIPS) Margin**
 - ❖ **Reduced Crud on fuel, improves Fuel Reliability (CILC)**
 - ❖ **Less Curies Generated and Available for Transport (CRUD)**

Initiative Value Proposition

- **Outage Performance**
 - ❖ **Critical Path Time Reduced**
 - ❖ **Incremental acceleration of every small task interfacing with RP Controls**
- **Stakeholder/ INPO-WANO/ Regulatory Risk**
 - ❖ **INPO/WANO Rankings**
 - ❖ **NRC: CIPS Margin Improved, Risk Reduction RP Related Violations**
- **Environmental Effluents (Radwaste)**
 - ❖ **Liquid Effluents -- Less Discharge of Curies --**
 - ❖ **Solid Waste-- Less Filters, Less Curie Surcharge, Less Costly Options for Disposal**
 - ❖ **Stakeholder Impact**

New Invention



- **US DOE R&D Laboratory for Nuclear Technology**
 - ❖ **Discover science and technology, where challenges are solved for the Medicine, Space, National security and Nuclear Technology**
 - ❖ **\$4 Billion R&D Annual Budget**
- **Los Alamos National Laboratory (LANL)**
 - ❖ **118 R&D 100 awards since 1978**
- **Invented and Patented, Polymer Filtration Technology™**
 - ❖ **Issued Exclusive World-Wide Grant of Licensed Inventions to (n,p) Energy, Inc.**
 - ❖ **R&D 100 Award-Polymer Filtration Technology**
- **(n,p) Energy, Inc. (NPE) Licensed Technology from LANL**
 - ❖ **NPE Engineered a 2 Part Solution**
 - **Part 1: Reactor Shutdown Protocol (Sequence)**
 - **Part 2: PRC-01M Resin Media for Rx Coolant Clean-up**

Los Alamos N.L. Science

R&D 100 AWARD Winner for Polymer Filtration Technology™

- What Los Alamos Can do, depending on your need
- Selective Capture and Removal of Specific Elements

Blue Box: Selective Binding Capability of LANL Inventions


Outlined Box: Relevant to NPP

H																	He
Li	Be											B	C	N	O	F	Ne
Na	Mg											Al	Si	P	S	Cl	Ar
K	Ca	Sc	Ti	V	Cr	Mn	Fe	Co	Ni	Cu	Zn	Ga	Ge	As	Se	Br	Kr
Rb	Sr	Y	Zr	Nb	Mo	Tc	Ru	Rh	Pd	Ag	Cd	In	Sn	Sb	Te	I	Xe
Cs	Ba	La	Hf	Ta	W	Re	Os	Ir	Pt	Au	Hg	Tl	Pb	Bi	Po	At	Rn
Fr	Ra	Ac															
		Ce	Pr	Nd	Pm	Sm	Eu	Gd	Tb	Dy	Ho	Er	Tm	Yb	Lu		
		Th	Pa	U	Np	Pu	Am	Cm	Bk	Cf	Es	Fm	Md	No	Lw		

How is PRC-01M Integrated?

Existing Plant Systems Chemical and Volume Control System (CVCS), Reactor Water Clean-up (RWCU), Fuel Pool Systems, Boron Recycle Systems and CANDU PHT

- PWR: PRC-1 (bead) or BWR: PRC-2 (powdered)
- Existing Plant Equipment



PWR
Deep Bed Vessel

- ❖ PWR: Uses CVCS Demineralizer Vessel
- ❖ Both: Spent Fuel Pool
- ❖ BWR: Filter/Demineralizers
 - RWCU
 - FPC
 - Torus
- ❖ CANDU
 - Primary Heat Transport



BWR
Precoat Filter/Demin



Lead Plants

NPE/PRC-01 Engineered Solution


- **PWRs 3 Loops**
 - ❖ Turkey Point-3,4
 - ❖ VC Summer
- **PWR 4 Loops**
 - ❖ DC Cook 1,2
- **BWRs**
 - ❖ Peach Bottom 2,3
 - ❖ Monticello
- **B&W:**
 - ❖ Davis Besse
- **CANDU:**
 - ❖ Bruce A/B

**Completed > 120 Refueling Outages
with NPE/PRC Engineered Solution In Service**

NPE Engineered Solution at USA, Mexico and Canada

PWR ...120 Refueling Outages

BWR7 Reactors...5 Sites...30+ Refueling Outages



PWR Results


Turkey Point-3,4

VC Summer

DC Cook-1,2

Davis Besse

QuickTime™ and a
decompressor
are needed to see this picture.



FPL 1st Integration 12 years Ago

#1 Turkey Point 3/2000, #2 St Lucie-1 4/2000 # 3 VC Summer

Pat-San →



PRC-01





Turkey Point-3,4 & VC Summer Source Term Approach: Only Use of PRC-01

- **Turkey Point 3,4:**
 - ❖ Yes: Chemistry pH(t) = 7.1
 - ❖ Yes: PRC-01 Media Technology
 - ❖ No: Zinc, No Fuel Cleaning, No Elevated pH 7.2 to 7.4
 - ❖ Fuel Duty: Middle Fuel Duty
 - ❖ 13 to 18 EFPY SG, Inconel 600 TT
- **VC Summer**
 - ❖ Yes: Chemistry pH(t) = 7.1
 - ❖ Yes: PRC-01 Media Technology
 - ❖ No: Zinc, No Fuel Cleaning, No Elevated pH 7.2 to 7.4
 - ❖ Fuel: High Duty, AOA Susceptible
 - ❖ 7 EFPY SG, Inconel 690 TT


FPL Turkey Pt-3R18 (1st PRC)

RCS Shutdown Co-58

100 hrs to Clean-Up Goal

$$1 \text{ E-3 } \mu\text{Ci/cc} = 37 \text{ Bq/cc}$$

Turkey Point U3
Shutdown Co-58 U3R18 (1st PRC) and R21 (4th PRC)




FPL Turkey Pt-3 R20 (3rd PRC)

Shutdown Co-58

70 Hours to Clean-Up Goal

$$1 \text{ E-3 } \mu\text{Ci/cc} = 37 \text{ Bq/cc}$$




FPL Turkey Pt-3R21 (4th PRC)


Last RCP Off - Before Peroxide Injection

Shutdown Co-58 56 Hrs to Clean-Up Goal

$$1 \text{ E-3 } \mu\text{Ci/cc} = 37 \text{ Bq/cc}$$



Turkey Pt 3,4 & VC Summer Sustained, Predictable Decline in Co-58 & Co-60 Shutdown Peak



$$1 \text{ uCi/cc} = 37 \text{ kBq/ cc}$$

Effective Dose Rate Trending

- **Effective Dose Rate = $\frac{\text{Total dose for the job (mrem)}}{\text{Total time for job (hour)}}$**

- **Good Analysis Tool for RFO to RFO Comparison**
 - ❖ **Permits comparison between refueling outages with different scope of work in containment**
 - ❖ **Valid if shielding practice is consistent**
 - ❖ **Valid if methods are consistent**


- **RWP = Radiation Work Permit**

- **1 mrem = 100 mSv**

FPL Turkey Pt-3


Sustained Decrease in Outage EDR

Overall Before/After PRC-01 = - 88.4%




Annual Liquid Effluent Discharges Co-58 and Co-60 Trend


Liquid Radwaste Processing System:
Activated Carbon, Conventional Resins- No Ultra-filtration or
Reverse Osmosis



Annual Liquid Effluent Discharges Fe-55 and Ni-63



Ag-110m Decline



FPL Turkey Pt. 3,4 & VC Summer Successful Source Term Reduction Summary

- **INPO Ranking Collective Exposure- Turkey Pt 3,4**
 - ❖ 4th Quartile in 2000, Avg RFO 140 to 160 REM
 - ❖ 1st Quartile in 2006, 1 Unit top Decile, 52.7 REM
 - ❖ INPO Good Practice for Source Term at Turkey Pt 3,4 and St. Lucie 1,2
- **INPO Ranking - VC Summer**
 - ❖ 3rd Quartile 2000, 140 to 160 REM
 - ❖ 1st Quartile 2006, RFO16 - 52 REM TLD
- **Effective Dose Rate Reduction**
 - ❖ 93.3% reduction in effective dose rate for Containment RWPS
 - ❖ 90% reduction in EDR for all RWPs
- **Avoided Occupational Radiation Exposure for multiple RFOs**
 - ❖ 325 REM (3.25 Sv) estimated of avoided occupational exposure for Turkey Pt U3, same for U4 LLW Disposal Reduction Curies and Disposal Costs
 - ❖ \$250,000 USD avoided per RFO in primary resin curie surcharge for Low Level disposal
- **Faster Shutdown Sequence**
 - ❖ 26 hours earlier for last RCPs to be taken out of service (O/S)

Turkey Point-3,4 Summary (cont.)

- - **60.0%**
 - ❖ Reduction in number of High Radiation Area
 - - **35%**
 - ❖ Reduction in contract HP staff, \$400,000 avoided costs every RFO.
 - - **76%**
 - ❖ Reduction in Hot Spots
 - - **49 X (fold)**
 - ❖ Reduction in annual effluent activity discharged for Co-58 and 15 fold for Co-60
 - - **87.7 %**
 - ❖ Reduction in Ni-63 annual effluent activity discharge, and 70% for Fe-55
- **1st World Record Low Dose Performance for U4 in 2005.**
 - ❖ **5.407 REM (54.07 mSv) U4 RVH**
 - **2nd World Record Low Dose Performance for U3 in 2005.**

Benchmarking Braidwood -1 Improving Performance



- **Braidwood-1 Implemented NPE/PRC Technology**

- A1R15 First Implementation
- A1R16 2nd Improved Implementation

- **Byron-1 Implemented Ortho-MacroPorous Resin**


- B1R15 3rd Use of Macroporous, 2nd Ortho Macroporous
- B1R16 Ortho Macroporous
- B1R17 Ortho Macroporous

NICKEL CORE		CRUD RELEASE/REMOVAL			
	Ni, [gr.]	% Change		Ni, [gr.]	% Change
A1R14	4012.000		B1R15	1936.000	
A1R15	3589.000	-10.5%	B1R16	3500.000	80.8%
A1R16	1467.00	-59.1%	B1R17	3212.00	-8.2%
Decreased CRUD			Increased CRUD =		
-63%			66%		


Braidwood A1R16 Source Term Success: SRMP


- A1R14 to A1R16 Significant Decline In Dose Rates in SG Manway Entrance and 3 ft
- SG Manway Entrance:
 - CL -44%, HL -53%
- Tubsheet MP:
 - CL -59%, HL -45%

Braidwood A1R14 to A1R16 Change in Steam Generator Manway Entrance Dose Rates
NPE/PRC Source Term Solution A1R15, A1R16
Hot Leg and Cold Leg by SG




Braidwood A1R14 to A1R16 Change in Steam Generator
3 ft from Manway Entrance Dose Rates
NPE/PRC Source Term Solution A1R15, A1R16
Hot Leg and Cold Leg by SG





BWR



Monticello R22 to R23 Results

PRC Use R22 RFO, Cycle, R23

April 2007

- **-28%**
 - ❖ Decline in BRAC Points
 - ❖ Main Circuit Piping- Standardized Locations
 - ❖ 2003 to 2007: Declined 28.5 %
- **-38.5%**
 - ❖ Decline RPV Effective Dose Rate
 - ❖ R22: EDR = 1.45 mRem/RWP-hr
 - ❖ R23: EDR = 0.89 mRem/RW-hr
 - ❖ Change: - 38.5 %
- **-71.1 %**
 - ❖ Fuel Floor (Fuel Move/Inspection/CRB Replace)
 - ❖ R22: 0.78 mRem/RWP-hr
 - ❖ R23: 0.21 mRem/RWP-hr
 - ❖ Change: - 71.1 %

Vermont Yankee R25 to R26 Results

PRC Use R25 RFO, Cycle, R25

May 2007

- **-28%**
 - ❖ Decline in A Recirc Suction
 - ❖ Main Circuit Piping- Standardized Locations
 - ❖ 2005 to 2007: Declined 28.5 %
- **-48.%**
 - ❖ Decline IVVI RWP Dose
 - ❖ 16.76 REM Planned IVVI RWP Dose
 - ❖ 8.172 REM Actual IVVI RWP Dose
 - ❖ Declined: -48%
- **-43.4 %**
 - ❖ Drywell RWP Dose
 - ❖ 21.21 REM Planned RWP Drywell Dose
 - ❖ 12.0 REM Actual RWP Drywell Dose



Radiation Safety Improvement Results

LANL/ NPE Engineered Solution for Reducing Source Term

- **Peach Bottom 3R 15 and 2R16 Drywell Dose Rates Reduced**
 - ❖ **Permitted Drywell Down Post from Locked High Radiation Area to High Radiation Area**
 - ❖ **Support Outage Performance**
- **Platform Post Removal Dose Rate**
 - ❖ **20 to 30 times Lower Dose Rate**
 - ❖ **(when Benchmarked to Limerick-1)**
- **Platform Contamination Levels**
 - ❖ **1000 times lower smearable contamination**
 - ❖ **(when Benchmarked to Limerick-1)**


- **PBAPS 3R17: Station Low Dose Record Achieved**
- **PBAPS 2R16: Station Low Dose Record Achieved**



BWRs

- **Application on Reactor Water Clean-Up (RWCU)**
 - ❖ **100% time**
 - ❖ **Refueling**
- **Expanding to Condensate Polishers**
 - ❖ **Start-up Rinse In**
 - ❖ **Expanding to On-Line Portion of CPS**

CANDU's: Bruce Power Bruce A/B




CANDU: BRUCE POWER

Operations-Maintenance-Chemistry

7 Element Solution- Media is 1 Element

Only as Effective as Weakest Link




Discovery: Bruce BU7 Activity Transport

Co-60 Increase 1,000 X, Sb-124 Increase 10,000 X

Bruce Power
Standard PHT
Ion Exchange Resin
Shows Almost No
Removal of
Co-60 or Sb-124
Entire Outage


U7 System PHT IX Clean up Performance
for Co-60 Outage Profile



Results: PHT System Bruce B-851 Outage Full System Operability Trial PRC-01M-Li-CN

Bruce U5 PRC Operability Field Trial During Start-up
PHT Clean-Up Co-60 DF with PRC-01-Li-CN In-Service
IX 6 Loading Configuration: 3 cu ft of PRC and 4 cu ft of Strong Base

Full Scale Operability Test
No DP Problems
No Sluice Problems
No D2O or De-Deut Problems
Lithiation Time
Max. DF=585 Co-60




◆ PHT Inlet Concentration
● PHT IX 6- PRC Outlet Concentration

Collaboration Opportunity for Asian Reactors

- **Technology Full Developed and Demonstrated Successful**
 - ❖ **More than 10 years of Operating Experience**
 - ❖ **Lead PWRs Now Lowest Dose Plants in US**
 - **DC Cook-1,2 4 Loop PWR Design**
 - **VC Summer, 3 Loop Design**
 - **Davis Besse, B&W Design**
- **BWR and CANDU Solution Developed**
 - ❖ **Monticello, Peach Bottom-2,3 BWR Design**
 - ❖ **Bruce B, Unit 8 CANDU Design**
- **Searching for a Lead Plant in Asia**
 - ❖ **Collaboration with US NPE Engineers and LANL**
 - ❖ **Exempt Technology Use License Fees**
 - ❖ **Please Express Interest to Ms. Robinson**


Thank You Very Much for Your Attention
ご清聴ありがとうございました



Parsing Zinc Injection vs. NPE/PRC Engineered Solution



- **EPRI Zinc GL: 0 to -15 % Dose Reduction, 35 ppb-mos**
 - Bugey 2, Sequoyah-2, Palisades and Seqyoyah-1 show no Dose Rate Reduction
- **Braidwood: -54% Dose Reduction with NPE PRC-01M**
 - All NPE/PRC Plants Show Significant and Sustained Dose Reduction, without Zinc Injection.



Reference: EPRI 1001020 plus new DCPD cycle 10 and data; A1R16 SRMP Average


Zinc Related Fuel Failures Documented By EPRI

Cost of Failure: Up to \$40M-\$80 M/event




- EPRI Fuel Reliability Program
- Zinc Injection Fuel Failures Recently Reported by EPRI
- “Take Action to Reduce CRUD on Fuel”


QuickTime™ and a decompressor are needed to see this picture.



QuickTime™ and a decompressor are needed to see this picture.



Metrics and Measures





CY 2000: First of a Kind Engineered Solution Developed for US PWRs

- **Early 1998... Collaboration Process Engaged**
 - ❖ **Florida Power and Light/ LANL/ NPE**
- **Florida Power and Light Turkey Point 3,4**
 - ❖ **Sponsored Research & Development -First of a Kind Engineering.**
 - ❖ **\$1.2 M Investment by Florida Power and Light**
 - ❖ **Developed Shutdown Sequence (Protocol) and PRC-01M Media**

B&W Design

QuickTime™ and a
decompressor
are needed to see this picture.

2011: Davis Besse- RVH Planned 128 REM; **Actual 40 REM**

RFO 16 to 17M - Two Core Rotations

Davis Besse EPRI Survey Data -
 Engineered Solution Implemented in RFO 15
 16 RFO to 17M (12 Month)

