

The Accident at Fukushima

Consequences of the Seaquake and Tsunami
for the Nuclear Power Plant Fukushima Daiichi


Thomas Linnemann, Dr.-Ing. Ludger Mohrbach



Contents

- **Power Supply System of Northern Honshu**
- **Consequences of the Tohoku Seaquake**
- **Layout of the Fukushima Daiichi Site**
- **Basic Accident Sequence of Events**
- **Short-Term Remedy and Measures**
- **Exposure Doses of Workers**






► System Border

50 Hz ► Northern Part,
60 Hz ► Southern Part.

- Only three frequency converter stations with limited total capacity of ≈ 1 GW.
- Seaquake-induced shutdown of large number of conventional power plants (hydroelectric and fossil-fired).
- Automatic shutdown of all nuclear power plants (11 units at 4 sites) in the northeastern part of Honshu.
- Installed Capacity (Tepco): ≈ 60 GW
- Available Capacity: ≈ 50 GW
- Capacity Loss (Disaster): ≈ 19 GW
- Remaining Capacity: ≈ 31 GW
- Total Load (Tepco): ≈ 41 GW
- Power Supply Gap: ≈ 10 GW



Blue

► Clouds.

Yellow

► Functioning lights before and after the natural disaster.

Red


► Power outages one day after the natural disaster compared to 2010 observation data.

Green

► Either clouds above areas of functioning lights after the natural disaster or lights not observed in 2010.

- Visible and infrared light spectrum.
- Widespread loss of electricity along northeastern coast of Honshu.
- Nearly 4 million homes and total area of 550 km² inundated by tsunami.





Epicenter Location


38,3 °N and 142,4 °O

Distances

- Onagawa ≈ 90 km
- F-Daiichi ≈ 160 km
- F-Daini ≈ 170 km
- Tokai ≈ 260 km
- Sendai ≈ 150 km

- **Magnitude 9.0** (measures energy released at the epicenter).
- **Intensity ≈ 11** (measures strength of shaking at a certain location, Japanese Scale: ≈ 7).

Peak Accelerations




Fukushima	Acceleration ¹⁾ in cm/s ²		
	Horizontal		Vertical
	N-S	E-W	
Daiichi-1	460	447	258
Daiichi-2	348	550	302
Beyond Design Basis		507	231
		319	200
		548	256
Daiichi-5	311	444	244
Daiichi-6	298		
Design Basis	441 to 487	438 to 489	412 to 429
Daini-1	254	230	305
Daini-2	243	196	232
Daini-3	277	216	208
Daini-4	210	205	288
Design Basis	415	415	504
Threshold	135 to 150		100


- Measured accelerations up to 26 % higher than earthquake design basis for Fukushima Daiichi ($\approx$ 10 % for Onagawa).



26 February 2011




13 March 2011



◄ Fukushima Daiichi ►


Fukushima Daiichi and Daini (10 units): 8946 MWe

► **Worldwide largest NPP site before the disaster.**



Unit	Power	Status ¹⁾
1	439 MWe	Operating
2	760 MWe	Operating
3	760 MWe	Operating
4	760 MWe	Outage
5	760 MWe	Outage
6	1067 MWe	Outage

¹⁾ before Sequake



Buildings and plant equipment close to unit 4



Local time

15:42

15:43


15:44

15:46

15:57

4 to 5 m inundation height above grade at units 1 to 4.





► Tsunami Design Parameters

- Original design basis
- 2002 Design basis review

► **3.1 m** maximum height.


► **5.7 m** maximum height.

► Additional Safety Margin


► **4.3 m** due to plant grade level of **10 m**.









- **Total loss** of external electrical power supply due to seaquake.
- **Successful start** and operation of emergency diesel generators.
- **Total loss** of emergency diesel generators/batteries (tsunami).
- **Dry out** of the reactor core by evaporation (decay heat).
- **Dropping water level**, exposure of hot metallic surfaces to steam, pressure and temperatures rise.
- **Steam release** via the safety relief valves into the wet well.
- **Temperature and pressure** increase in the wet well.



Units 1 to 4

- No recombiners for severe accident conditions (units 1 to 4).
- Hydrogen explosion inside the reactor service floor (1, 3, 4).
- Destruction of steel framework structures in upper part (1, 3, 4).
- Intact reinforced concrete buildings.
- Substantial core damages (1 to 3).
- Dry out of spent fuel pools?



- ▶ Emergency generators at high elevations or in watertight bunkered buildings and watertight connections between emergency power supplies and plant.
- ▶ Robust design of cooling and venting systems which may also be manipulated and operated without power (e.g. regarding valves).
- ▶ Power trucks should be kept close on or very close to the nuclear power plant site.
- ▶ Independent and secured battery systems to power crucial instrumentation during emergencies.
- ▶ Passive catalytic hydrogen recombiners designed to cope with hydrogen releases under severe accident conditions.
- ▶ Passive filters on vent lines to remove radioactivity and allow for venting without harming nearby residents (no evacuation).
- ▶ **Regulatory quality and independence.**



► Is Fukushima Daiichi a matter of **residual risk** of nuclear energy?

Date	Affected Region	Earthquake ¹⁾	Tsunami ²⁾
11.03.2011	Japan	M = 9.0	39 m
04.10.1994	Kuril Islands	M = 8.3	11 m
12.07.1993	Sea of Japan	M = 7.7	31.7 m
26.05.1983	Noshiro	M = 7.7	14.5 m
07.11.1896	Sea of Japan	M = 8.4	24 m
02.01.1868	Kuril Islands	M = 8.5	10 m
01.01.1868	Kuril Islands	M = 8.5	10 m
07.01.1868	Kuril Islands	M = 8.5	10 m
15.01.1868	Kuril Islands	M = 8.5	10 m
24.12.1854	Nankaido	M = 8.4	28 m
29.06.1780	Kuril Islands	M = 7.5	12 m
24.04.1771	Ryukyu Islands	M = 7.4	85 m
28.10.1707	Japan	M = 8.4	11 m
31.12.1703	Tokaido-Kashima	M = 8.2	10.5 m
02.12.1611	Sanriku	M = 8.0	25 m
20.09.1498	Nankaido	M = 8.6	17 m
Resulting Actual Design Basis		M ≈ 7.4	> 10 m

Even with earthquake magnitudes as low as 7.4 (equivalent) a large tsunami with a maximum height above ≈ 10 m can be produced!

► Analysis of Historical Data

16 large tsunamis with wave heights of at least 10 m in past 513 years.

► Experienced Frequency

$$f = \frac{16}{513 \text{ a}} \approx 0.0312 \text{ a}^{-1} \approx \frac{1}{30 \text{ a}}$$

Thus, within a **thirty years period** one large tsunami must be expected somewhere in Japan!

► Site-Specific Frequency

Within a **100 to 1 000 years period** one large tsunami must be expected at every coastal location in Japan (**Fukushima: 300 to 400 years**).

► No, it is rather a matter of having underestimated a high specific risk!





NISA Regulatory Requirements

- Improvement of accident management (diesels, cables, hose connections ...)
- **New tidal barriers with watertight doors.**

Example

NPP Kashiwazaki Kariwa






July 11, 2011: New Shelter Building for Unit 1

September 11, 2011



September 11, 2011: Additional Cooling System for Unit 3





Range Classification	Number of Engaged Workers March 2011 to April 2012		
Cumulative Dose ¹⁾	Tepco	Contractors	Total
250 mSv or more	6	0	6
200 to 250 mSv	1	2	3
150 to 200 mSv	22	2	24
100 to 150 mSv	117	17	134
50 to 100 mSv	449	376	825
20 to 50 mSv	614	2 428	3 042
10 to 20 mSv	493	2 893	3 386
10 mSv or less	1 715	12 499	14 214
Total	3 417	18 217	21 634
Maximum Dose	678.80 mSv	238.42 mSv	678.80 mSv
Average Dose	24.77 mSv	9.53 mSv	11.94 mSv

► Concluding Summary:

- **9 workers 200 to 670 mSv,**
- 158 workers 100 to 200 mSv,
- other workers less than 100 mSv.

► Statistical Population Data:

- Natural risk of death from cancer of total population: 25 %
- Risk of death from cancer of **fuming** population: 35 %
 - **10 % higher natural risk of death from cancer for smokers!**

► Increased statistical risk of death from late cancer by radiation according to linear Dose-Risk-Relationship (ICRP):

- 200 mSv: + 2 %
- **670 mSv: + 6.7 %**

Thank you for your attention!

Dipl.-Ing. Thomas Linnemann

Thomas.Linnemann@vgb.org

Dr.-Ing. Ludger Mohrbach

Ludger.Mohrbach@vgb.org

VGB PowerTech e.V.

Klinkestraße 27 - 31, 45136 Essen, Germany

Telefon: +49-(0)2 01-81 28-0 (Zentrale)

Telefax: +49-(0)2 01-81 28-3 50

Vertretungsberechtigter Vorstand: Prof. Dr. Gerd Jäger

Registergericht: Amtsgericht Essen

Registernummer: VR 1788

www.vgb.org