



Potential Impacts

Terry J. Brown, CHP, RSO, PMP
Projects Director DC Cook Nuclear Station

January 9, 2012

Today's Agenda

- NRC approach to prioritize the Fukushima Near Term Task Force (NTTF). Tier 1, Tier 2, and Tier 3
- Cook response
- Why is response needed





NRC Approach

- Developed team (Fukushima Near Term Task Force – NTTF) to review nuclear safety and provided recommendation to commission.
- No recommended actions raised level of actions to be taken without delay.
- Developed a priority system to address based on greatest potential for safety improvement in the near term.



NRC Approach

- TIER 1 should be started without unnecessary delay and for which sufficient resource flexibility, including critical skill sets, exists.
- TIER 2 could not be initiated in the near term due to factors that include need for further technical assessment and alignment.
- TIER 3 require further staff study to support regulatory action

NRC Approach

- TEIR 1 recommendations
 - Seismic & flood hazard reevaluations
 - Seismic & flood walkdowns
 - Station blackout (SBO) regulatory actions
 - Equipment covered under 10CFR50.54 (hh)(2).
 - Reliable hardened vents for Mark I & II containments.
 - SFP Instrumentation
 - Integrations of EOPs, SAMGs, and extensive damage mitigation guidelines
 - EP regulator action (staffing & communication)



Diverse and Flexible Mitigation Capability (FLEX)

- Additional layer of safety to mitigate beyond design bases events
- Focuses on maintaining key safety functions
 - Core cooling, containment integrity, SFP cooling
- Multiple supplies of power and cooling water
- Portable equipment reasonably protected
- Symptom based guidance and instruction
- Regional support centers



DC Cook Response

Extended Loss of AC Power

General Solution Path

- Enter Loss of All AC procedure
- Deep Load Shedding
- Connect Temporary Power
 - 120 VAC generators to power local instrumentation for controlling SG pressure and level

COOK NUCLEAR PLANT

- 600 VAC generators to power battery chargers
- 120 VAC generators to critical control room power panels in each control room



DC Cook Response

Planned Equipment Purchases

- Two diesel driven raw water pumps as backup to B.5.b pumper truck (ordered)
 - Suction from Forebay
 - Can provide water to SGs and/or the Spent Fuel Pit
- Westinghouse shutdown seals (The SHIELD®)
 - Scheduled for U1C25 and U2C21 (spring and fall of 2013)
 - Significant improvement in risk profile
 - Limits RCP seal leak to 1 gpm vs. 21 gpm on loss of cooling
- Two mobile (towable) 600vac / 500kW diesel generators
 - Power 600 V busses



DC Cook Response

Planned Equipment Purchases

- Twelve portable 120vac / 5kW to 10kW diesel generators
 - Power Logic Safety Injection (LSI) panels, Control Room Instrumentation and Distribution (CRID) and Critical Control Room Power (CCRP) inverters
- Portable refueling tanker trailer
 - 500 gallon capacity with fuel oil transfer pump
- Communications equipment
 - Satellite phones, pagers, additional batteries





Cook built dual unit main control room simulators

- Allows integrated dual unit EP Scenarios.
- Cook Facility also has new state-ofthe-art four, rear projection plant parameter display emergency response training facility.





COOK NUCLEAR PLANT

Industry

Industry Developments

- Shared Equipment Distribution Center concept
 - INPO surveyed plants on their existing equipment and intended purchases
- NEI and industry providing significant input
- Good high level alignment thus far between regulator and industry
- Also responding to INPO IER





- Earthquake occurred in Virginia near the North Anna site.
- Units shutdown and diesels provided emergency power.
- Units not restarted until November 2011 after a comprehensive site wide safety evaluation was completed.



- Heavy Snowfall in Montana: Photo Taken June 17, 2011
- Spring Snow Melt
 Flows to Missouri &
 Mississippi Rivers.







 Fort Calhoun PWR Station Nebraska, USA









 Cooper BWR Station on Mississippi River, Summer 2011

