

NATC CZT Data Analysis Working Group Achievements

Derek Hultquist – Health Physicist, & David W. Miller, NATC Regional Director, D.C. Cook,
American Electric Power
2016 ISOE Asian ALARA Symposium
Fukushima, Japan, September 7-9, 2016

Overview


1. **Summary of August 24-26, 2016 CZT Data Analysis Working Group Meeting held at Cook**
2. **Examples of CZT 3D isotopic mapping analyzed by group:**
3. FF/Primary to Secondary Leakage
4. Foreign Material Investigation
5. Particle Investigation / Mitigation
 1. General
 2. Transfer Canal Job Coverage

Failed Fuel & Primary-to-Secondary Leakage Tracking

- D. C. Cook has failed fuel and current primary-to-secondary leakage in U2
- U1 has completed an outage (U1C27) with failed fuel

Failed Fuel & Primary-to-Secondary Leakage Tracking



- Tracking & Investigation with CZT
- New Library: Noble Gases / Iodines / Corrosion Products
- Low energy – Lack of imaging



Isotope	Energy (keV)	Branching Ratio (%)
Cs-134	604.721	97.62
	795.864	85.46
Cs-137	661.657	85.1
I-131	364.49	81.7
I-133	529.87	87
	834.83	13
Sb-124	1529.77	10.9
	602.726	98.3
	722.784	10.81
Sb-125	1690.97	47.57
	427.875	29.6
	463.365	10.5
	600.6	17.9
Xe-135	635.954	11.3
	250	90.2
	526.56	80.6
Xe-135m	258.4	31.5
	434.56	20.3
	1768.26	16.7
Zr-95	724.192	44.27
	756.725	54.38

Failed Fuel & Primary-to-Secondary Leakage Tracking


- Not always traceable



HED 16-191_u2_sg_bypass_line; 2:42:48

*Not a bad "0"


Failed Fuel & Primary-to-Secondary Leakage Tracking




We **power** life's possibilitiesSM




Increased Dose Rates in VCT




Increased Dose Rates in VCT



Increased Dose Rates in VCT




Increased Dose Rates in VCT




HED 24304 Imaged Cts; Xe-135; 16-043_vct_618_; 10:06

*Trace with energies > 250 keV if possible, preferably short half-lives


VCT bypass Vent hose to Vent Stack



Charging Pump Rotor Replacement



Charging Pump Rotor Replacement




Charging Pump Rotor Replacement

Engineered Controls worked


No PCM/PM Alarms

No Uptakes (Lapel)

Charging Pump Rotor Replacement



Charging Pump Rotor Replacement




SFP Exhaust Trend


- Failed Fuel Bundle in SFP
- Track Release
- Should drop off with no delta-P

SFP Exhaust Trend


8 day half-life




4/5/16



4/12/16




4/18/16



We power li 4/28/16 tiesSM



SFP Exhaust Trend



We **power** life's possibilitiesSM




Foreign Material Analysis

- Foreign material found during outage
- Approximately the size of a fingernail
- Contact exposure of 16 R/hr w/
Telepole
- CZT estimated exposure rate of 100-
200 mR/hr 30 inches away.

Foreign Material Analysis

- 3 minute, 25 second duration
- 72.7% dead time
- 56 second live time
- The lowest counts seen in a peak energy region was 55,750 for Fe-59
- Only Activation Products seen


Foreign Material Analysis




We **power** life's possibilitiesSM



Foreign Material Analysis



Foreign Material Analysis




Activity Contributions


vve **power** life's possibilitiesSM



Foreign Material Analysis



Foreign Material Analysis



Foreign Material Analysis

Isotope	Half-Life	Gamma Energy	Intensity	Back calculated Activity	Back Calculated % Activity
Co-60	5.27 years	1173 keV	99.97%	7.68 mCi	2.78%
		1332 keV	99.99%		
Cr-51	27 days	320 keV	9.92%	253.8 mCi	91.86%
Fe-59	44.5 days	1099.25 keV	56.5%	5.3 mCi	1.92%
		1291.6 keV	43.2%		
Mn-54	312.3 days	834.8 keV	99.98%	9.52 mCi	3.45%

The initial calculated activity was determined by assuming that criticality ended at 3/23/16 for a duration of approximately 30.5 days ($t-t_0$) between end of criticality and the measurement. Activity was calculated by using the equation below.

$$A = A_0 * e^{-\frac{0.693}{T}(t-t_0)}$$


Foreign Material Analysis

- Results indicate high chromium and iron, with very low or non-existent nickel content.
- Not believed to be RCS/Fuel Component Related
- Not the cause of failed fuel. Leak location and size indicate foreign material would likely be on the order of a wire bristle


Particle Investigation / Mitigation

- Cook has a history of legacy or ghost particles with no known origin
- Whole Aux. Building CA at one point
- CZT used to search for contamination


Particle Investigation / Mitigation: Seal Table Eddy Current



Particle Investigation / Mitigation






HED 2861 Imaged Cts; Co-60; 16-105_u1_seal_table; 10:10



HED 594 Imaged Cts; Cs-137; 16-105_u1_seal_table; 10:10




Particle Investigation / Mitigation

TESCA Seal: Moving Material




Particle Investigation / Mitigation

TESCA Seal: Moving Material




Particle Investigation / Mitigation


TESCA Seal: Moving Material



HED 13461 Total Cts; 70 Selected Cts; (3 of 10) 16-119_u1_u_c_airlock_tecsas; 14:52 Detected Selected




HED (3 of 10) 16-119_u1_u_c_airlock_tecsas; 14:52




Particle Investigation / Mitigation Gray Steel Move

Stud Racks are to the right of the detector. Low level contamination (<100 ccpm) found




HED 812201 Total Cts; 1962 Selected Cts; 16-153_650_SFP_gray_steel; 3:



HED 758 Imaged Cts; Co-60; 16-153_650_SFP_gray_steel; 3:37:12


Particle Investigation / Mitigation Hot Chem Lab Percon



We **power** life's possibilitiesSM



Particle Investigation / Mitigation Hot Chem Lab Percon



Transfer Canal Job Coverage



Challenges

- Alpha Level III (First in Cook History)
- HCA/RPA
- Infrequently Entered (Previous Entry was 2007)
- Multiple particles found during surveys
 - 1 Percon attributed to the project

Transfer Canal Job Coverage


- Coverage techs used CZT to validate contamination control
- Documented in RP Survey Program
- Used with other tools
 - Airflow test
 - Masslinn / Tacky Roller / Surface Covers

Transfer Canal Job Coverage



Particle Search – Red is
Check Source, Particle found
on scaffold



Transfer Canal Job Coverage




We **power** life's possibilitiesSM



Transfer Canal Job Coverage



Transfer Canal Job Coverage




HED 319 Imaged Cts; Cs-137; 15-372_xfer_canal; 1:08:06

We **power** life's possibilitiesSM



Transfer Canal Job Coverage




POI previously HEPA, now man basket




HED 4348 Imaged Cts; Co-60; 15-377_Transfer_Canal_CA_U1_side; 6:09:46

Transfer Canal Job Coverage



HED 154814 Total Cts; 3468 Selected Cts; 15-390_650_Transfer_Ca




HED 700 Imaged Cts; Co-60; 15-390_650_Transfer_Canal_U2_side; 47:04


We **power** life's possibilitiesSM



Transfer Canal Job Coverage



HED 257 Imaged Cts; Cs-137; 15-390_650_Transfer_Canal_U2_side; 47:04



HED 153 Imaged Cts; Nb-95; 15-390_650_Transfer_Canal_U2_side; 47:04

We **power** life's possibilitiesSM



Questions?



We **power** life's possibilitiesSM

