

ISOE INFORMATION SHEET

**OCCUPATIONAL EXPOSURE AND
STEAM GENERATOR REPLACEMENTS**

ISOE European Technical Center - CEPN Information Sheet No. 1

Within the framework of the ISOE system (international Information System on Occupational Exposures), five NEA 3 questionnaires concerning recent steam generator replacements have been supplied to the ISOE data base. These are supplemented by other data taken from the literature, from utilities reports and from the ELECNUC data base of French Atomic Energy Agency.

This ISOE Information Sheet presents an overview of the exposures and main characteristics of all the Steam Generator

Replacements (SGR) which have been performed in the world through December, 1993. It also shows the impact of a SGR on the total collective dose after a SGR.


1. SGR Collective Exposures

The first Steam Generator Replacement took place at Surry unit 2 in 1979. Table 1 presents the collective exposures corresponding to the seventeen steam generator replacements performed (for a total of fifty steam generators) from 1979 to 1993.

Table 1. Steam Generator Replacements (SGR) from 1979 to 1993

| Country | Plant unit | Replacement year | No. of Loops replaced | Total Collective Dose (manSv) | Collective Dose per SG (manSv) |
|-------------|-----------------|------------------|-----------------------|-------------------------------|--------------------------------|
| USA | Surry 2 | 1979 | 3 | 21,41 | 7,14 |
| USA | Surry 1 | 1980 | 3 | 17,59 | 5,86 |
| USA | Turkey Point 3 | 1981 | 3 | 21,51 | 7,17 |
| USA | Turkey Point 4 | 1982 | 3 | 13,05 | 4,35 |
| Germany | Obrigheim | 1983 | 2 | 6,90 | 3,45 |
| USA | Point beach 1 | 1983 | 2 | 5,90 | 2,95 |
| USA | H.B. Robinson 2 | 1984 | 3 | 12,06 | 4,02 |
| USA | D.C. Cook 2 | 1988 | 4 | 5,61 | 1,40 |
| USA | Indian Point 3 | 1989 | 4 | 5,41 | 1,35 |
| Sweden | Ringhals 2* | 1989 | 3 | 2,90 | 0,97 |
| France | Dampierre 1* | 1990 | 3 | 2,13 | 0,71 |
| USA | Palisades | 1990 | 3 | 4,87 | 1,62 |
| USA | Millstone 2 | 1992 | 3 | 6,70 | 2,23 |
| USA | North Anna 1* | 1993 | 3 | 2,40 | 0,80 |
| Switzerland | Beznau 1* | 1993 | 2 | 1,10 | 0,55 |
| Belgium | Doel 3* | 1993 | 3 | 1,96 | 0,65 |
| France | Bugey 5 | 1993 | 3 | 1,55 | 0,52 |

*: NEA3 questionnaire existing in the ISOE database



Fig

Figure 1. Evolution of steam generator replacement collective doses

As can be seen, the SGR collective exposure has been regularly decreasing, showing the impact of feed back experience: total and per steam generator collective doses of the last SGR in France are 14 times lower than those received during the first SGR at Surry 2 in USA (Figure 1 and Table 1).

collective dose during the three prior years with refuelling outages. The collective dose following replacement falls to approximately 50 % of the pre-replacement collective dose. Thus, from the first refuelling outage year after the SGR, the extra exposure due to the SGR has largely been recovered.

Figure 2 indicates the number of SGR performed in each country.

2. Impact of SGR on Post SGR Annual Exposure

The method used to determine the impact of SGR on post-SGR annual collective doses is presented on page 3. Based on this selection criteria, only six reactors are used in the following study. Analysis of the data shows that, on average, collective dose during the steam generators' replacement year is 70 % higher than the average




Figure 2. Number of SGR performed per country from 1979 to 1993.

Figure 3 presents this average evolution assuming a normalised average collective dose, prior to SGR, of 100.

Figure 4 gives the information for each of the six reactors concerned [Robinson 2 (USA), Indian Point 3 (USA), Palisades (USA), Obrigheim (Germany), Ringhals 2 (Sweden),

Dampierre 1 (France)]. Considering this figure, it is noticeable that evolutions of occupational exposures are similar for all the reactors under study.




Figure 3. **Average impact of a SG replacement on the evolution of the reactor annual collective dose** [number of data considered for the average calculation]

METHOD FOR THE ANALYSIS

Recent steam generators replacements (performed in 1993) have not been taken into account in establishing Figures 3 and 4 presented in this ISOE Information Sheet, because annual collective doses concerning the post-SGR years are not available. Moreover, only the reactors for which the total annual collective exposure is given per reactor (not total exposure for the site) are kept for the analysis.

The analysis method is the following : in order to determinate if steam generator replacement has had an impact on the evolution of post-SGR annual collective exposure of a reactor, only the years with refueling outages have been considered. The reference period is composed of the last three refueling outage years before the steam generator's replacement. The average dose over these three years then represents the collective exposure received by the workers before the steam generator's replacement. For comparison with other reactors, this average collective exposure is normalized to 100. Collective exposures of the steam generator's replacement year and of the years, with refueling outages, following the SGR are also similarly normalized.

It should be noted that for the american reactors (Indian Point 3 and Palisades), only the two years before the SGR have been taken into account as the third year includes a refuelling outage of approximately one year, which is four times longer than the normal duration. Furthermore, the lower exposure level observed at Palisades during the SGR year can be partly explained by the fact that the SGR took place during two calendar years and by the fact that the considered year counted only 74 % of the collective exposure due to the SGR.

ISOE CEPN Information Sheet No. 1 - May 1994




Figure 4. **SG replacements and evolutions of the annual collective doses** (basis 100 = 3 last refuelling outage years average collective dose)

3. Some Characteristics of SGR

Some important characteristics of steam generator replacements are summarised in Table 2.

Different materials have been chosen by the plants for the steam generator tubing :

since 1983, Inconel 690 TT has often been specified as a replacement for Inconel 600. Incoloy 800 is selected by Siemens, and it was used in Germany and for the Doel 3 SGR.

Table 2. **Some characteristics of Steam Generators replacements**

| Plant unit | Total or partial replacement | New SG tubes material | Primary piping | |
|----------------|------------------------------------|-----------------------|----------------|----------------|
| | | | No of cuts/SG | Cutting method |
| Surry 2 | Lower section | Inconel 600 TT | 5 | Plasma |
| Surry 1 | Lower section | Inconel 600 TT | 5 | Plasma |
| Turkey Point 3 | Lower section without channel head | Inconel 600 TT | - | |
| Turkey Point 4 | Lower section without channel head | Inconel 600 TT | - | |
| Obrigheim | Entire SG | Incoloy 800 | 4 | Machining |
| Point beach 1 | Lower section | Inconel 690 TT | 2 | Plasma |
| Robinson 2 | Lower section without channel head | Inconel 690 TT | - | |
| D.C. Cook 2 | Lower section | Inconel 690 TT | 2 | Plasma |
| Indian Point 3 | Entire SG | Inconel 690 TT | 2 (3) | Plasma |
| Ringhals 2 | Entire SG | Inconel 690 | 4 | Machining |
| Dampierre 1 | Entire SG | Inconel 690 TT | 2 | Plasma |
| Palisades | Entire SG | Inconel 600 | 5* | Machining |
| Millstone 2 | Lower section | Inconel 690 TT | 2 | |
| North Anna 1 | Lower section | Inconel 690 TT | 2 (3) | Machining |
| Beznau 1 | Entire SG | Inconel 690 TT | 4/5** | Machining |
| Doel 3 | Entire SG | Incoloy 800 | 3 | Machining |
| Bugey 5 | Entire SG | Inconel 600 TT | 2 | Machining |

Lower section means steam generator lower assemblies including tube bundles

TT denotes Thermally treated

* : Cold legs 2 cuts each, hot leg one cut.

** : 4 cuts SG A, 5 cuts SG B.

4. Some Protection Actions during last SGRs

Tables 3 gives for the last six SGRs, the type of decontamination of primary piping and the total weight of lead shielding installed for the SGR.

Through these figures, it is clear that radioprotection is a major concern during such types of operation. In order to reduce

the dose rates, classical actions remain very important:

- the total amount of lead shielding installed during SGR is as high as 80 t,
- no SGR is performed without a decontamination of parts of the primary circuit.

The most recent decontamination actions involved only the primary pipes into and out of the steam generator channel head, and were performed after the removal of the old steam generators.

Table 3. Protective Actions during SGRs

| Plant unit | Decontamination process | Components decontaminated and length | Dose rate reduction factor range | Total weight of lead shielding (t) |
|-------------------|--|---|---|---|
| Ringhals 2 | Electropolishing | 0.5 m of Primary Pipe ends after Old SG removal | N.A. | 25 |
| Dampierre 1 | Electropolishing in 2 SG | 1,5 m of Primary Pipe ends after Old SG removal | 3,5 to 4 in the steam generator cubicle | 56 |
| | Chemical decon in 1 SG (LOMI process) | Channel head & 1.5 m of Primary Pipe ends before Old SG removal | 2.7 in the steam generator cubicle | |
| North Anna 1 | Mechanical blasting with Aluminium Oxide followed by glass beads | 0.5 m of Pipe ends after Old SG lower section removal | 23.2 to 51.5 at the pipe end plane (post shielding) | 70 |
| Beznau 1 | Mechanical process (Blasting process) | Pipes ends over 400 mm length after Old SG removal | N.A. | 80 |
| Doel 3 | Sand blasting with electro-corundum | Pipe ends after Old SG removal | 45 to 80 at the pipe end plane | 60 |
| Bugey 5 | Chemical decontamination (EMMA process) | 1.55 m Primary Pipe ends after Old SG removal | 3 to 11 in the steam generator cubicle | 55 |